

# Swimming and spa pool fencing

## Inspection form

### Property details (All fields are mandatory)

Owner/occupier:

Date:

22/06/12

Address:

23 Wapiti Avenue  
Epsom

Phone:

### The Fencing of Swimming Pools Act 1987

The act requires all pool owners, occupiers or tenants to fence the immediate pool area. This means the land in or which the pool is situated and as much of the surrounding area that is used for activities or purposes related to the use of the pool. This includes spas. The fence should be situated to prevent children moving directly to the pool from the house, other buildings, garden paths and other areas of the property that would normally be available to young children. Refer to full schedule overleaf.

If your pool does not comply, the Fencing of Swimming Pools Act 1987 requires the pool to be emptied immediately until it does comply.

### Comments on inspection

Pool type:



Swimming pool



Spa

SWP number:

Reason for inspection:



LIM



Audit



Recheck



Complaint

### Comments

does not comply, refer section 6 of the schedule overleaf.

work to be addressed and the property re-inspected by 21 days time

please feel free to contact Council to book your re-inspection with me

Result of inspection:



Complies. No further action required at this date.



Does not comply. Rectify faults immediately.

All remedial work needs to be completed within 21 days of the inspection. If work is not satisfactorily completed by the second inspection, a fee will be incurred.

Inspection to follow in 21 days or if you wish to book this at a particular time, please call Auckland Council on 09 353 9143.

For more information go to [www.aucklandcouncil.govt.nz/poolfencing](http://www.aucklandcouncil.govt.nz/poolfencing)

Inspection by: (please print)

Jeremy Hurman

Signature:

Blb 16/07/12

# Swimming pool fencing


The Fencing of Swimming Pools Act 1987

Date: 22/06/12.

Address: 23 Wapiti Avenue, Epsom

Reference No:

## Site sketch



① trellis on neighbours side of boundary fence exceeds the 50mm maximum allowed & is therefore deemed climbable, I suggest talking with your neighbour to either remove or cover with a non-climbable material to a height of 1.2M. Alternatively isolate the fencing.